

LOCATION 1116 Laurel Woods CITY GASTONIA

BETWEEN Candlewood Dr. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>107'</u>	<u>4-8-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>92'</u>			

ENTERS: 1116 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 600 PSI _____ INCHES W.C. LOCATION 289' E. of center of

Candlewood Dr.


PRESSURE TEST: @ 160 PSI FOR 1/4 HRS. BY S. Huff-Slett

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION 15' S. of center of Laurel Woods Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 216870

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY