

LOCATION 1250 Laurel Woods Dr. CITY Columbia  
 BETWEEN See Jay Ct STREET & Graywood Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	Ø	134'	4-11-02		
MAIN TO PROP LINE	3/8"	f	54'	"		
PROP LINE TO BLDG	5/8"	Ø	80'	"		

ENTERS 1250 BRANCHED INTO Ø  
 TAP SIZE 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 363' south

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY J. Woody of See Jay Ct.


MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3' FT 0" IN LOCATION 20' East of center of Laurel Woods Dr.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 0080730

REMARKS New plastic service

(40' bore)



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>11.65V</u>
P/S Pipeline Lead - White Existing Main	E	<u>1.5V</u>