

LOCATION 1310 Laurel Woods Dr CITY Gastonia  
BETWEEN See Jay Ct STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>5/8</u>	<u>P</u>	<u>141</u>	<u>8-26-02</u>		
MAIN TO PROP LINE	<u>1"</u>	<u>1"</u>	<u>50</u>			
PROP LINE TO BLDG.	<u>1"</u>	<u>1"</u>	<u>91</u>			

ENTERS 1310 Laurel Woods Dr BRANCHED INTO N/A

TAP SIZE 3/4 PRESSURE 60 PSI INCHES WC LOCATION 886' South of C. or

Left Side of 1310 Laurel Woods Dr See Jay Ct.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY J. Cook


MAIN SIZE 2 C.I.  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED

DEPTH 3 FT 0 IN LOCATION 234' East of center of

Laurel Woods Dr

"A" P/S READING N/A TOTAL ANODES 1#  17#  L.R. #

REMARKS RAN New 5/8 PLASTIC Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	