

LOCATION 2509 Lower Ct CITY Castonia

BETWEEN Kennedy Rd STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>90'</u>	<u>3-4-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>80'</u>			

ENTERS: 2509 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 148' W. of center of

Kennedy Rd


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffer

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 FT. 0 IN. LOCATION 23' N. of center of Lower Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 117987

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY