

LOCATION 2515 LAVER CT CITY Castania
BETWEEN Kennedy Rd. STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>190'</u>	<u>3-4-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>190'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>80'</u>			

ENTERS: 2515 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 21' S. of center of
LAVER CT


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstetter

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 FT. 0 IN. LOCATION 169' W. of center of Kennedy Rd

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 117988

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY