

LOCATION 1527 Lavington Ct. CITY CASTONIA  
BETWEEN Indigo Run STREET & Cul-de-Sac STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>72'</u>	<u>3-5-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>62'</u>			

ENTERS: 1527 BRANCHED INTO  
TAP SIZE 1/2 PRESSURE 100 PSI \_\_\_\_\_ INCHES W C LOCATION 209' W. of center of Indigo Run.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY SGK  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED \_\_\_\_\_  
DEPTH: 3 FT 0 IN LOCATION 14' S. of center of Lavington Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 163388

REMARKS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	