

LOCATION 4604 Lendon Hall Ct. CITY Gastonia
 BETWEEN Abbotsford STREET & Reed and STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>83'</u>	<u>4-7-99</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>9'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>74</u>			

ENTERS: 4604 BRANCHED INTO: -
 TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 20' E of Cop
Lendon Hall
 PRESSURE TEST: 100 PSI FOR 1/4 HRS BY SP
 MAIN-SIZE 2 1/2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
 DEPTH: 3 FT 0 IN LOCATION _____
 "A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____
 REMARKS _____

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

