

LOCATION 4708 Lenden Hall Ct. CITY Gastonia

BETWEEN Abbotsford Ct STREET & Cul-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	74'	2-23-98		
MAIN TO PROP. LINE	3/4"	P	15'			
PROP. LINE TO BLDG.	3/4"	P	59'			

ENTERS: 4708 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 163' SE. of center of

Abbotsford Ct


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hurt

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION 32' NE of center of Lenden Hall Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 106199

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY