

LOCATION 513 Lehigh Ave CITY Coastal
BETWEEN Boyce STREET & Morris STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	36'			8/19/96
MAIN TO PROP. LINE	3/4"		5'			
PROP. LINE TO BLDG.	3/4"		31'			

ENTERS: 513 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION W side of 513

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT
MAIN SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996
DEPTH: 1 FT. 6 IN. LOCATION S side of 513

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 414980

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY