

LOCATION 515 Lenox Ave CITY BASTONIA  
BETWEEN Boyce STREET & Morris STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>88'</u>			<u>8/3/92</u>
MAIN TO PROP. LINE	<u>3/4"</u>		<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>78'</u>			

ENTERS: 515 BRANCHED INTO:  
TAP SIZE: 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC / YEAR INSTALLED 1994

DEPTH: 2 FT. 6 IN. LOCATION \_\_\_\_\_

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 414980

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY