

LOCATION	2205 Leroy Ave.			CITY	COSTONIA	
BETWEEN	Azalea Ave.		STREET &	N. New Loop Rd		STREET
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	50'	5-8-95		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	40'			

ENTERS: 2205 BRANCHED INTO:

TAP SIZE: 1/2	PRESSURE 60 P.S.I.	INCHES W.C.	LOCATION 74' S. of center of Leroy Ave.
---------------	--------------------	-------------	---


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffstiller

MAIN SIZE 3/4"	C.I. _____	BARE STEEL _____	COATED STEEL <input checked="" type="checkbox"/>	PLASTIC _____	YEAR INSTALLED _____
----------------	------------	------------------	--	---------------	----------------------

DEPTH: 1 Ft. 6 In. LOCATION 269' W. of center of Azalea Ave.

"A" P/S READING .4 TOTAL ANODES 1\* 1 17\* 0 L.R. # 219110

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY