

LOCATION 2021 Leake Dr. CITY Los Angeles
BETWEEN Ashton Place STREET & Leake St STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>133</u>	<u>2-28-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>43</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>90</u>			

ENTERS: 2021 BRANCHED INTO:
TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION Waste House

PRESSURE TEST: @ 100 psi For 14 Hrs. By J. Smith
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED 1958
DEPTH: 2 Ft. 6 In. LOCATION 18' S/Capt

"A" P/S READING .80 TOTAL ANODES 1* 17 * 1 L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY