

LOCATION 2027 Leslie Dr. CITY East.
BETWEEN Ashton Pl. STREET & Linda St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>39' / RECOVER</u>		<u>7-9-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>				
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>				

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 221' From (A) OF Ashton Pl.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992
DEPTH: 3 FT. 0 IN. LOCATION SOUTHside of LESLIE Dr.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY