

LOCATION 5021 Lewis Rd CITY Gastonia

BETWEEN Chapelwood DR STREET & Holly Hills DR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>25'</u>			<u>10-3-95</u>
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>25'</u>			

ENTERS: 5021 BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 118' S. of center of Chapelwood DR


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffaker

~~MAIN~~ SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 2 Ft. 0 In. LOCATION 135' E. of center of Lewis Rd.

"A" P/S READING 1.0 TOTAL ANODES 1* 0 17* 0 L.R. # 501378

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY