

LOCATION 5244 Lewis Rd CITY GASTONIA
BETWEEN Branding Iron Dr. STREET & Old Church Rd STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	116'	7/8/97		
MAIN TO PROP. LINE	3/4"		29'			
PROP. LINE TO BLDG.	3/4"		87'			

ENTERS: 5244 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION North side of 5244

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT
MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED 1964
DEPTH: 3 FT. 0 IN. LOCATION East side of Lewis Rd

"A" P/S READING 170 TOTAL ANODES 1# _____ 17# 1 L.R. # 460447

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY