

LOCATION 5523 Lewis Rd. CITY GASTONIA  
BETWEEN Freedom Mill STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>D</u>	<u>330</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>D</u>	<u>50</u>			<u>7-8-99</u>
PROP. LINE TO BLDG	<u>3/4</u>	<u>D</u>	<u>280</u>			

ENTERS 5523 BRANCHED INTO 0  
TAP SIZE 3/8 PRESSURE 60 PSI INCHES W.C. LOCATION

PRESSURE TEST 100 PSI FOR 1/4 HRS BY EP

MAIN SIZE 6" C.I.        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 81

DEPTH 4 FT 0 IN LOCATION

"A" P/S READING 16 TOTAL ANODES 1# 17# L.R. #

REMARKS  
no anode installed  
on Rectifier system

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

