

LOCATION

BETWEEN

MAIN TO BLDG.

MAIN TO PROP. LINE

PROP. LINE TO BLDG.

SIZE

TYPE

LENGTH

INSTALLED

RETIRED

RENEWED

3/4

P

3'

Tied over

280' of EA

3/4" W to EA 2" Plastic

Main

5-23-95

ENTERS:

BRANCHED INTO: 0

TAP SIZE:

1/2

PRESSURE

20

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST: @

100

psi

For

1/2 Hrs.

By

EP

MAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1993

DEPTH:

2 Ft.

6 In.

LOCATION

"A" P/S READING

P


TOTAL ANODES 1#

17#

L.R. #

REMARKS:

Tracer wire tied off at main
Banded Insulated Cables



Test Station

ENG. DEPT. USE ONLY

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New ServiceS
P.S.W.

1.2

P/S Pipeline Lead - White
Existing Main

E