

LOCATION 105 S. Liberty CITY Canton  
BETWEEN W. Main STREET & W. Franklin St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>48'</u>		<u>Renewed</u>	<u>12-12-96</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>43'</u>			

ENTERS: 105 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 600 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 105 PSI FOR 1/4 HRS. BY EP  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1992  
DEPTH: 3 FT. 6 IN. LOCATION \_\_\_\_\_

"A" P/S READING Diagram TOTAL ANODES 1# ✓ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Diagram</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		