

LOCATION 316 S. Liberty ST CITY GAstonia
BETWEEN 2nd Ave STREET & 3rd ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	65'	2-13-96		
MAIN TO PROP. LINE	3/4"	P	30'			
PROP. LINE TO BLDG.	3/4"	P	35'			

ENTERS: 316 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 283' N. of center of 3rd ST.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. W. F. S. S. S.
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1991
DEPTH: 3 Ft. 0 In. LOCATION 15' W. of center of S. Liberty ST.

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 56640

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY