

LOCATION 113 W. Lincoln Ave. CITY GASTONIA

BETWEEN Marietta St. STREET & Lincoln Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>95'</u>	<u>2-6-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>55'</u>			

ENTERS: 113 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 383' W of Coy Marietta St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1989

DEPTH: 2 FT. 6 IN. LOCATION 17' N of Coy Lincoln Ave.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 I.R. # 048957

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Rise Plastic</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>		

