

Water Bar

LOCATION 117 West Lincoln CITY Gastonia
 BETWEEN Marietta STREET & N. Falls STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>36'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>4'</u>			<u>12-10-98</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>32'</u>			

ENTERS: 115 BRANCHED INTO: 117
 TAP SIZE: 3/4 IN. PRESSURE: 100 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY EP
 MAIN SIZE: 3/4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1996
 DEPTH: 1 FT. 6 IN. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY