

LOCATION 512 W. Lincoln Ave.CITY GASTONIABETWEEN BoyceSTREET & MORRIS

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	94'			
MAIN TO PROP. LINE	3/4	P	30'	10-7-95		
PROP. LINE TO BLDG.	3/4	P	64'			

ENTERS: 512BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 20 P.S.I. _____ INCHES W.C.

LOCATION

PRESSURE TEST: @ 100 psi For 44 Hrs. By EPMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993DEPTH: 3 Ft. 6 In. LOCATION"A" P/S READING P TOTAL ANODES 1* 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY