

LOCATION 611 W Lincoln Ave. CITY Gastonia
BETWEEN Pryor St. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P.</u>	<u>22 ft</u>			<u>1-13-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>2 ft</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>20 ft</u>			


ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 336^{ft} From (1) of Pryor St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H.f
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION Southside of West Lincoln Ave.

"A" P/S READING Plastic TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY