


LOCATION 3320 Lincoln Ln CITY GASTONIABETWEEN Crosscreek STREET & Cul-d-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	102'	12/16/96		
MAIN TO PROP. LINE	3/4"		10'			
PROP. LINE TO BLDG.	3/4"		92'			

ENTERS: 3320 BRANCHED INTO:TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION North side of 3320PRESSURE TEST: @ 100 PSI FOR 14 HRS. BY DTMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED 1979DEPTH: 3 FT. 0 IN. LOCATION East side of Lincoln Ln"A" P/S READING 1.20 TOTAL ANODES 1# 0 17# 0 L.R. # 721475

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY