

LOCATION 3526 Lincoln Ln. CITY GASTONIA
BETWEEN GASTON DAY School Rd STREET & STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG. | 3/4" | P | 98' | 3-20-95 | | |
| MAIN TO PROP. LINE | 3/4" | P | 5' | | | |
| PROP. LINE TO BLDG. | 3/4" | P | 93' | | | |

ENTERS: 3526 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 186' N. of center of
GASTON DAY School Rd.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFBETH
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1994
DEPTH: 3 Ft. _____ In. LOCATION 20' E. of center of L. Lincoln Ln.

"A" P/S READING 7 TOTAL ANODES 1# 0 17# 0 L.R. # 122259

REMARKS:



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY