

LOCATION 3530 Lincoln Ln. CITY GASTONIA

BETWEEN GASTON DAY School Rd. STREET & HEARSHAW DR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>115'</u>	<u>1-3-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>110'</u>			

ENTERS: 3530 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I.          INCHES W.C. LOCATION 146' N. of center of

GASTON DAY School Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFBLER

MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 Ft. In. LOCATION 20' E. of center of LINCOLN LN.

"A" P/S READING P TOTAL ANODES 1\* 0 17\* 0 L.R. # 578218

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY