

LOCATION 3531 Lincoln Ln. CITY Gastonia

BETWEEN Gaston Day School Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>158'</u>	<u>11-4-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>43'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>113'</u>			

ENTERS: 3531 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 213' N. of center of Gaston Day School Rd.


PRESSURE TEST: @ 100 psi For 44 Hrs. By S. Huff & Son School Rd.

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 Ft. 0 In. LOCATION 19' E. of center of Lincoln Ln.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 625627

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY