

LOCATION 2197 Linda Dr CITY Gastonia

BETWEEN Audrey STREET & Leslie STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>	<u>7'</u>	<u>Relocated</u>	<u>6-21-96</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 21197 BRANCHED INTO: 0

TAP SIZE: 3/4 sec PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST: @ 105 PSI FOR 44 HRS. BY EP

MAIN SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH: 2 FT. 6 IN. LOCATION \_\_\_\_\_

"A" P/S READING 1.1 TOTAL ANODES 1# 1 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R. Sec</u>	<u>1.1</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY