

LOCATION 2220 Linda St. CITY GASTONIA
BETWEEN LESLIE DR. STREET & ASHTON ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>124'</u>		<u>7-</u>	<u>16-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>119'</u>			

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 184' FROM (A) OF
LESLIE DR.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 3 FT. 0 IN. LOCATION EAST side of LINDA ST.

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY