

LOCATION 315 Linden cir CITY Gast.
 BETWEEN Broad st. STREET & Linden cir 300 STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>27'</u>			<u>9-30-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>24'</u>			


ENTERS: SAME BRANCHED INTO: 313 Linden cir
 TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 270' From @ of Linden Circle

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.
 MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION E. OF Linden cir

"A" P/S READING P. TOTAL ANODES 1# 17# L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY