

LOCATION 1308 Linberger Ave CITY Gastonia
BETWEEN 12th STREET & Hillcrest STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>80'</u>	<u>5-27-95</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>40'</u>			

ENTERS: 1308 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 18' w. of Cap
Linberger

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY GP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY