

LOCATION 1409 Linberges S CITY GASTONIA
BETWEEN Hillcrest STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	52'			1/10/98
MAIN TO PROP. LINE	3/4"		20'			
PROP. LINE TO BLDG.	3/4"		32'			

ENTERS: 1409 BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY D J
MAIN-SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998
DEPTH: 1 FT. 6 IN. LOCATION

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 010443

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY