

LOCATION 1414 Lineberger St

CITY Gastonia

BETWEEN Hillcrest

STREET &amp; Dearden

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	plastic	23'	1-14-98	Tied over 135'	Ext 3/4 Plastic
MAIN TO PROP. LINE					Service to New	21' Plastic main
PROP. LINE TO BLDG.					with 23' of Plastic Pipe	

ENTERS: 1414

BRANCHED INTO:

TAP SIZE: 3/4	PRESSURE 60 PSI	INCHES W.C.	LOCATION
---------------	-----------------	-------------	----------


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE

MAIN-SIZE 2 1/2	C.I.	BARE STEEL	COATED STEEL	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED 1997
-----------------	------	------------	--------------	---	---------------------

DEPTH: 3 FT. 0 IN.	LOCATION
--------------------	----------

"A" P/S READING Plastic	TOTAL ANODES 1# 17#	L.R. #
-------------------------	---------------------	--------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	Riser	plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY