


LOCATION 1415 Linberger St CITY GASTONIABETWEEN Hillcrest STREET & STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|---------|--------|-----------|---------|----------|
| MAIN TO BLDG. | 3/4" | Plastic | 69' | | | 11/10/98 |
| MAIN TO PROP. LINE | 3/4" | | 9' | | | |
| PROP. LINE TO BLDG. | 3/4" | | 60' | | | |

ENTERS: 1415 BRANCHED INTO:TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION South side of 1415PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DTMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN. LOCATION West side of Linberger St"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 010443

REMARKS:



| Test Station | | |
|--------------------------------------------|----------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |

ENG. DEPT. USE ONLY