

LOCATION 1415 Line Berger CircleCITY EastonBETWEEN Dead endSTREET & Hillcrest

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/W</u>	<u>4'</u>	<u>2-2-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>C/W</u>	<u>0'</u>	<u>2-2-96</u>		
PROP. LINE TO BLDG.	<u>3/4</u>	<u>C/W</u>	<u>4'</u>			

ENTERS: #415BRANCHED INTO: 0

TAP SIZE: <u>3/4</u>	PRESSURE <u>20</u> P.S.I.	INCHES W.C.	LOCATION
----------------------	---------------------------	-------------	----------

PRESSURE TEST: @ 100 psi. For 6 Hrs. By EDMAIN-SIZE 3/4 C.I.     BARE STEEL ✓ COATED STEEL     PLASTIC     YEAR INSTALLED    DEPTH: 1 Ft. 6 In. LOCATION    "A" P/S READING 11.6 TOTAL ANODES 1 \* 2 17 \* 0 L.R. #    

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>R. 3 in.</u>	<u>1.5</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY