


LOCATION <u>310 Linsbury Ct.</u>		CITY <u>Castanville</u>	
BETWEEN <u>Creek Ridge Dr</u>		STREET & <u>Cul-de-Sac</u>	
	SIZE	TYPE	LENGTH
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>102'</u>
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>57'</u>
ENTERS <u>310</u>		BRANCHED INTO	
TAP SIZE <u>3/4"</u>	PRESSURE <u>60</u> PSI	INCHES W C	LOCATION <u>384' SW of center of Creek Ridge Dr</u>
PRESSURE TEST @ <u>160</u> PSI FOR <u>44</u> HRS BY <u>S.H.</u>			
MAIN-SIZE <u>3"</u>	C I	BARE STEEL	COATED STEEL
DEPTH <u>3</u> FT	<u>0</u> IN	LOCATION <u>18' S. of center of Linsbury Ct</u>	PLASTIC <input checked="" type="checkbox"/> YEAR INSTALLED
"A" P/S READING <u>P</u>		TOTAL ANODES 1# <u>0</u> 17# <u>0</u> LR #	
REMARKS			



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White	<u>E</u>	