

LOCATION 318 Linsbury Ct CITY Gastonia  
BETWEEN Creek Ridge Dr. STREET & Cal-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>		<u>9-5-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>55'</u>			

ENTERS 318 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 223' SW. of center of Creek Ridge Dr.


PRESSURE TEST @ 100 PSI FOR 4 HRS BY SL

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 17' NW. of center of Linsbury Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 827014

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	