

LOCATION 319 LINSBURY CT. CITY GASTONIA  
BETWEEN CREEK RIDGE STREET & CW. DO - SAL STREET

|                   | SIZE        | TYPE     | LENGTH     | INSTALLED      | RETIRED | RENEWED |
|-------------------|-------------|----------|------------|----------------|---------|---------|
| MAIN TO BLDG      | <u>5/8"</u> | <u>P</u> | <u>87'</u> | <u>10.2.01</u> |         |         |
| MAIN TO PROP LINE | <u>"</u>    | <u>"</u> | <u>5'</u>  |                |         |         |
| PROP LINE TO BLDG | <u>"</u>    | <u>"</u> | <u>82'</u> |                |         |         |

ENTERS 319 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 600 PSI \_\_\_\_\_ INCHES W.C. LOCATION S. side of house


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY BK

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT IN LOCATION S. W. side of road

"A" P/S READING N/A TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ LR # \_\_\_\_\_

REMARKS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



| Test Station                               |          |       |
|--|----------|-------|
| Reading & Location                         | Lead     | Volts |
| P/S Pipeline Lead - Red<br>New Service     | <u>S</u> |       |
| P/S Pipeline Lead - White<br>Existing Main | <u>E</u> |       |