

LOCATION 327 Linsbury Ct. CITY GASTONIA
BETWEEN Creek Ridge Dr. STREET & Cut-Off St. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG | 3/4" | P | 76' | 7-23-01 | | |
| MAIN TO PROP LINE | 3/4" | P | 5' | | | |
| PROP LINE TO BLDG | 3/4" | P | 71' | | | |


ENTERS 327 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 356' S. of center of Creek Ridge Dr.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. of
MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION 18' W. of center of Linsbury Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 586072

REMARKS



| Test Station | | |
|--|------|-------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | S | |
| P/S Pipeline Lead - White Existing Main | E | |