

LOCATION 334 Linsbury CT CITY Castonia
BETWEEN Creek Ridge Dr. STREET & Putnam St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>45'</u>	<u>7-12-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>50'</u>			


ENTERS 334 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 112' S. of path of Creek Ridge Dr

PRESSURE TEST @ 100 PSI FOR 14 HRS BY S. G.
MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 2' FT 0 IN LOCATION 18' W of center of Linsbury CT

"A" P/S READING P TOTAL ANODES I# 0 17# 0 LR # A0555501

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	