


LOCATION	401 Linsbury Ct			CITY	Gastonia	
BETWEEN	Hickory Hollow Rd.			STREET &	Creek Ridge Dr	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	70'	3-17-00		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	67'			
ENTERS:	401			BRANCHED INTO:		
TAP SIZE:	3/4"	PRESSURE	60 PSI	INCHES W.C.	LOCATION 44' N. of center of Creek Ridge Dr.	
PRESSURE TEST:	@ 100 PSI	FOR 1/4 HRS	BY S.K.			
MAIN-SIZE	4"	C.I.	BARE STEEL	COATED STEEL	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED 2000
DEPTH:	3 FT.	0 IN.	LOCATION 16' W. of center of Linsbury Ct.			
"A" P/S READING	P			TOTAL ANODES 1#	0	17# 0
					L.R. # 179643	
REMARKS:						



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	W	