

LOCATION 408 Linsbury Ct. CITY Gastonia

BETWEEN Hickory Hollow Rd STREET & Creek Ridge Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>124'</u>	<u>3-17-00</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>55'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>69'</u>			

ENTERS: 408 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 78' S. of center of Hickory Hollow Rd.


PRESSURE TEST: @ 60 PSI FOR 1/4 HRS. BY S.G.

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH: 3 FT. 0 IN. LOCATION 16' W. of center of Linsbury Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 179471

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>I</u>	