

LOCATION 319 Linwood Rd. CITY CRASHEN  
BETWEEN GARRISON BL STREET & 2nd Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>42'</u>	<u>Replaced</u>		<u>2-3-01</u>
MAIN TO PROP LINE						
PROP LINE TO BLDG						

ENTERS 319 BRANCHED INTO 0  
TAP SIZE 3/4 IN. PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST @ 100 PSI FOR 4 HRS BY ED

MAIN SIZE 3/4 IN. C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED \_\_\_\_\_

DEPTH 2 FT 4 IN LOCATION \_\_\_\_\_

"A" P/S READING Plastic TOTAL ANODES 1# 17 LR # \_\_\_\_\_

REMARKS \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	