

LOCATION 408 &amp; 408 1/2 Linwood Rd

CITY GastoniaBETWEEN GarrisonSTREET & 4th St.

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	10'	8-27-94	Replaced 16' 3/4" w/ Ser	
MAIN TO PROP. LINE					to Ext 4" P. Main	
PROP. LINE TO BLDG.						

ENTERS: 408BRANCHED INTO: 1/2TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 26' W. of C ofLinwoodPRESSURE TEST: @ 100 psi For 1/4 Hrs. By CPMAIN-SIZE 4" C.I.      BARE STEEL      COATED STEEL      PLASTIC ☒ YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In. LOCATION"A" P/S READING P TOTAL ANODES 1# 1 17#      L.R. #     REMARKS: tie wire off at main

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.50</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY