

LOCATION

603 Linwood Rd

CITY

Easton

BETWEEN

W5th

STREET &

Spencer

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	78	Thick over 8-27-94		
MAIN TO PROP. LINE	3/4	"	2			
PROP. LINE TO BLDG.	3/4	"	76			

ENTERS:

603

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

Spencer house

PRESSURE TEST: @

100

psi

For

1/4

Hrs.

By

Bennett

MAIN-SIZE

4

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1994

DEPTH:

2 Ft.

6 In.

LOCATION

22' W of C. Rd


"A" P/S READING

TOTAL ANODES 1#

17#

L.R. #

REMARKS:

Bare Main Replacement
Program

Test Station

ENG. DEPT. USE ONLY

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	