

LOCATION 802 & 720 Linwood Rd CITY Easton
BETWEEN Conrad STREET & EAST D STREET

	SIZE	TYPE	LENGTH	INSTALLED	-RETIRED-	-RENEWED-
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>56'</u>	<u>7-9-94</u>	<u>Tied over</u>	<u>143' to Ext</u>
MAIN TO PROP. LINE					<u>3/4 Plastic</u>	<u>to Ext 4"</u>
PROP. LINE TO BLDG.					<u>Plastic main</u>	


ENTERS: 802 BRANCHED INTO: 720
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 psi For: 1/2 Hrs. By: F.D.
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993
DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:

P.S. Reading on #720 is 1.2



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY