

LOCATION 906 + 908 Linwood Rd CITY Gastonia  
BETWEEN East STREET & Conrad STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>64'</u>	<u>7-9-94</u>	<u>Tied over</u>	<u>54' Existing 3/4"</u>
MAIN TO PROP. LINE					<u>Plastic Service to existing</u>	
PROP. LINE TO BLDG.					<u>4' Plastic</u>	<u>Main</u>

ENTERS: 906 BRANCHED INTO: 908

TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 130' N of C of East


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION 32' W of C of Linwood Rd

"A" P/S READING plastic TOTAL ANODES 1\* - 17\* - L.R. # 292850

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY