

LOCATION 1402 LinwoodCITY GASTONIA

BETWEEN

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>114</u>	<u>7-9-94</u>	<u>Tie-over</u>	<u>to 4" Plastic</u>
MAIN TO PROP. LINE					<u>w/3' 3/4 plastic</u>	
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 66 South of
Monument


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. _____ In. LOCATION 18 West of Linwood

"A" P/S READING _____ P. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY