

LOCATION 1504 S. Linwood CITY Gastonia  
BETWEEN John Ave STREET & JVA STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>50'</u>	<u>7-23-94</u>	<u>Tied over</u>	<u>75' of Ext</u>
MAIN TO PROP. LINE					<u>3/4" Chw to Ext 4"</u>	
PROP. LINE TO BLDG.					<u>Plastic Main</u>	

ENTERS: 1504 BRANCHED INTO 0  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 psi For 44 Hrs. By EP  
MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993  
DEPTH: 3 Ft. 6 In. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS: Tie in with tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R.S.</u> <u>R. 3er</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY