

LOCATION 1708 Linwood Rd CITY Gastonia  
BETWEEN Cloverdale STREET & Drewwood STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>7-16-94</u>	<u>tried over 100' 3/4 G/W Sec.</u>	
MAIN TO PROP. LINE					<u>to Ext 4' P. Main</u>	
PROP. LINE TO BLDG.						

ENTERS: 1708 BRANCHED INTO: ~

TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 20' N. of C of  
Linwood Rd


PRESSURE TEST: @ 100 psi For 1/2 Hrs. By JP

MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1\* \_\_\_\_\_ 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>1.500</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY